

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

VIPA GmbH

Ohmstraße 4, 91074 Herzogenaurach, Germany

the Certificate No: **Z10348** for the PROFINET IO Device:

Model Name: VIPA 053-1PN00
Revision: SW/FW: V1.3.2; HW: 2
GSD: GSDML-V2.3-VIPA-SLIO-20131015.xml
Identnumber: 0x022B; 0x18C5
DAP: DAP 1: 053-1PN00 Profinet Device, 0x0A000C00

This certificate confirms that the product has successfully passed the certification tests with the following PROFINET scope:

<input checked="" type="checkbox"/> Hardware	Auto_Negotiation, Auto_Polarity, Auto_Crossover
<input checked="" type="checkbox"/> Conformance Class B	RT_CLASS_1, RTA, LLDP, SNMP, MIB-II, LLDP-MIB

Test Report Number: PN150-2
Authorized Test Laboratory: SIEMENS AG, Fürth, Germany


The tests were executed in accordance with the following documents:
 "Test Specifications for PROFINET IO devices, Version 2.2.4 from December 2010",
 "Test Cases for PN-Tester for PROFINET IO devices, Version 2.2.4.16.21".

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS and PROFINET products".
 For all products that are placed in circulation by November 11, 2016 the certificate is valid for life.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)

(K.-P. Lindner)